

Government of Bihar
Public Health Engineering Department
Water Quality Report

Name:- Public Health Engineering Division, Nawada

Name of School		Date of Sampling :- 30-01-2024											Source of water
Source Water		Test Report											Source of water
5	6	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	ALK	NO ₃	F	18
St. Joseph's school, Roh	RO	6.72	0.65	235	158	128	20	15	28	135	1	0.25	Filter water
		6.5-8.5	1.0	500	500	200	75	30	250	200	45	1.0	
Source		NR	5.0	2000	2000	600	200	100	1000	600	NR	1.5	

B. Singh
6/2/24
AE, Nawada

[Signature]
6/2/24
 Executive Engineer
 P.H. Division, Nawada