

Government of Bihar
Public Health Engineering Department
Water Quality Report

District:- Nawada

Sample code:- DLWTL/NWD/W/26-27/123

Sample Collected by:-ST.Joseph's school (Md.Dilshad)					Date of Sampling:18-05-2026												
Sl. NO	Block	Panchayat	Village	Name of Place	Test Report											Source of water	Remarks
					pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	ALK	F			
1	2	3	4	6	7	8	9	10	11	12	13	14	15	16	17	18	
1	Roh	Samahrigadh	Sahopar	ST. Joseph's School Sahopur,Roh	7.41	1.13	1035	673	348	99.54	23.52	122	360	0.47			
Desirable Limit* (IS10500:2012)					6.5	1.0	500	500	200	75	30	250	200	1.0			
Permissible Limit* in absence of alternate source					8.5	5.0	2000	2000	600	200	100	1000	600	1.5			

[Signature]
19.05.2026
Chemist

P.H. Division, Nawada

[Signature]
19.05.26

Assistant Engineer
P.H. Sub Division, Nawada

[Signature]

Executive Engineer
P.H.Division, Nawada

[Signature]
19/05/2026